



* FOR ALUMINIUM OR STEEL SUBSTRUCTURE CAVITY DEPTH IS MIN 20 mm
 IN CASE FACADE HAS OPEN JOINTS AND PRESSURE EQUALISATION IS USED,
 ROCKPANEL RECOMMENDS A CAVITY DEPTH OF 40-100 mm

Detail 2-212B

Junction vertical joint
 onto an aluminium or steel substructure

